



2009 IECC Residential Energy Code Duct Test Form

Project Address: _____

Builder/Designer: _____ Phone: _____

MECHANICAL SUMMARY: Duct Tightness Verification (DTV)

DTV Test Conducted by: _____ Certification #: _____
(Certifier's Name)

Certifier's Phone #: _____

Unless all ducts are located within conditioned space, must verify one of the following:

- Post-construction total duct leakage (PCT) is $\leq 4\%$
- Rough-in total duct leakage (RIT) with air handler installed is $\leq 4\%$
- Rough-in total duct leakage without air handler installed (RITnah) is $\leq 3\%$

System	Test (PCT, RIT, RITnah)	CFM ₂₅	Area served (ft ²)	Result (%)	Comments
1					
2					
3					

(% Duct Leakage Result = $CFM_{25} \times 100 /$ Conditioned floor area served)

*****POST THESE RESULTS IN A SAFE VISIBLE LOCATION*****

(i.e. inside cabinet door or electrical panel)

****DTV Test is mandatory and results shall be submitted to Permit Office prior to Final Building Inspection by Fax at (337) 437-4100 or e-mail to permits@cppj.net ****